

2019 ANNUAL DRINKING WATER QUALITY REPORT

JOHNSTON COUNTY WATER LINE CUSTOMERS (FIRETOWER ROAD) PWS# 40-51-006

The Annual Drinking Water Quality Report for 2019 is below for your review. This yearly report shows the quality of drinking water that the Town of Pine Level Purchases from Johnston County and delivers to you every day. Please review this report and should you have any questions, please contact Ray Stuckey at the Pine Level Town Hall at 919-965-2284.

Contaminant Group	Frequency	Last Sample Date	Results	Next Sample Date	Source of Contamination
Microbiological					
Total Coliform Bacteria Fecal Coliform Bacteria	Once Monthly	June 2020	Absent	July 2020	Total coliform naturally present in the environment Fecal coliform and human And animal fecal waste.
Disinfectants and Disinfectant Byproducts (D?DBP) Rule (TTHM) Total Trihalomethane (THAAS) Total Habacetic Acids	Quarterly	May 2020	.091	August 2020	Byproducts from use of disinfectants such as chlorine
Nitrate	Annually	April 2018	0.513	by Dec. 2020	Run-off from fertilizer use Leaching from septic tanks
Lead and Copper	Annually	June-Sept 2018	Below Action Level	June-Sept 2021	Corrosion of household plumbing systems, erosion Of natural deposits leaching From wood preservatives.
Asbestos	Every 9 yrs.	1-31-2012	N/D	1-1-2021	

IMPORTANT DRINKING WATER DEFINITIONS:

Non-Detects (ND) – Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used
Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

This institution is an equal opportunity provider and employer. Discrimination is prohibited by Federal Law. To file a complaint of discrimination, write USDA, Assistant Secretary for Civil Rights, 1400 Independence Avenue SW, Stop 9410, Washington, DC 20250-9410 or call toll-free at (866)632-9992 (English) or (800)877-8339 (TDD) or (866)377-8642 (English Federal relay) or (800)845-6136 (Spanish Federal-relay)